



Product Service

# CERTIFICATE

No. Z2 122259 0002 Rev. 00

**Holder of Certificate:** **IPCOM ROADS s.r.o.**  
K Lukám 1071/19a, Libuš  
142 00 Prague  
CZECH REPUBLIC

**Certification Mark:**



**Product:** **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 701262318701-00

**Valid until:** 2028-08-01

**Date,** 2023-08-04

( Zhulin Zhang )



Product Service

# CERTIFICATE

No. Z2 122259 0002 Rev. 00

## Model(s):

QPM-xxxS, xxx = 630 to 660 in steps of 5  
QPM-xxxS, xxx = 580 to 600 in steps of 5  
QPM-xxxS, xxx = 540 to 560 in steps of 5  
QPM-xxxS, xxx = 495 to 510 in steps of 5  
QPM-xxxS, xxx = 450 to 465 in steps of 5  
QPM-xxxS, xxx = 405 to 420 in steps of 5  
QPM-xxxT, xxx = 560 to 585 in steps of 5  
QPM-xxxT, xxx = 515 to 535 in steps of 5  
QPM-xxxT, xxx = 470 to 490 in steps of 5  
QPM-xxxT, xxx = 420 to 440 in steps of 5  
xxx is standing for rated output power at STC

## Parameters:

Construction: Framed, with Junction box  
Cable and Connectors.  
Test Laboratory: Yangzhou Opto-Electrical  
Products Testing Institute  
No. 10 West Kaifa Road, Yangzhou  
225009 Jiangsu, P. R. China  
Safety Class: Class II  
Maximum System Voltage: 1500 V DC  
Fire Safety Class: Class C according to UL790

## Tested according to:

IEC 61215-1:2016  
IEC 61215-1-1:2016  
IEC 61215-2:2016  
IEC 61730-1:2016  
IEC 61730-2:2016